From: Joshua Hill
To: Danny Mapili - WPD-C
Cc: Terry Lamb Sr.; Todd Williams; Patrick J. Murray; Kaan Dilber; Andrea Mango; Edwin Lopacki - WPIB
Subject: RE: FERC Swing: Status of Design Review
Date: Friday, July 15, 2016 6:07:18 PM
Attachments: image001.png

Danny,

Below are our comments:

On A301, we may need an additional wireless access point located in the vicinity of the entrance to the suite (see drawing below).

Also, I do not see where the low-voltage cabling is included anywhere, either in the drawings or specifications. We had discussed this being included in the construction work.



Josh D. Hill, RPA | Director, Logistics Management Division
Phone: 202.502.6159 | Mobile: 202.590.7812 | Email: Joshua.Hill@ferc.gov

---

From: Joshua Hill
Sent: Friday, July 15, 2016 1:52 PM
To: 'Danny Mapili - WPD-C' <danny.mapili@gsa.gov>
Cc: Terry Lamb Sr. <terry.lamb@ferc.gov>; Todd Williams <Todd.Williams@ferc.gov>; Patrick J. Murray <pmurray@akridge.com>; Kaan Dilber <Dilber@otj.com>; Andrea Mango <Mango@otj.com>; Edwin Lopacki - WPIB <tony.lopacki@gsa.gov>
Subject: RE: FERC Swing: Status of Design Review

I'll have it to you today

Josh D. Hill, RPA | Director, Logistics Management Division
Phone: 202.502.6159 | Mobile: 202.590.7812 | Email: Joshua.Hill@ferc.gov

From: Danny Mapili - WPD-C [mailto:danny.mapili@gsa.gov]
Sent: Friday, July 15, 2016 7:56 AM
To: Joshua Hill <Joshua.Hill@ferc.gov>
Cc: Terry Lamb Sr. <Terry.Lamb@ferc.gov>; Todd Williams <Todd.Williams@ferc.gov>; Patrick J. Murray <pmurray@akridge.com>; Kaan Dilber

<Dilber@otj.com>; Andrea Mango <Mango@otj.com>; Edwin Lopacki - WPIB <tony.lopacki@gsa.gov>
Subject: FERC Swing: Status of Design Review

Good morning Josh,
I would like to check the status of the Design Review for the 100%CD's FERC Swing.

Thanks

Danny C. Mapili
Project Manager (Contractor)
Office of Design and Construction
NCR-PBS U.S. General Services Administration
Room 7919 (Station 7360)
P 202-219-0376 | M 703-678-8289